


## An Innovative Approach to Emergency Response Planning

CES501695


Susan Knepper, PE
Water Resources Engineer | @OHMAdvisors

Tim Medearis, PE Solutions Engineer, Autodesk



### City of Livonia, Michigan

- Located in Northwest Wayne County
- Michigan's ninth most populated municipality
- Approximately 36 square miles
- Population: 95,535






#### **Water System**

- Approximately 485 miles of water main
- Diameter range: 6" to 36"
- Age range: 1920's to present
- Material: cast iron, ductile iron, HDPE, concrete, and asbestos cement
- Purchases water from the Great Lakes Water Authority (GLWA)

Demand Scenario	Demand (MGD)	
Average Day	11	
Maximum Day	21	
Peak Hour	29	






#### **GLWA System**

- Newburgh Pump Station
- West Service Center
- Schoolcraft Pump Station
- West Chicago Pump Station
- Master Meter Feeds (8)

0	LV-02	0	LV-13
0	LV-03	0	LV-14
0	LV-04	0	LV-15
0	I \/_12	0	I \/_16





# Pressure Reducing Valves (12)

PRV-01

PRV-06


PRV-02

PRV-07

PRV-03

- PRV-10
- PRV-04 & PRV-04BPRV-11 & 11B
- PRV-05


PRV-12





## **Pressure Districts (4)**

- North
- Northwest
- West
- East






### **Hydraulic Modeling History**





### **Hydraulic Model Usage**

- Water master planning/capital planning
- Water main permitting basis of design
- Pressure checks
- Fire protection checks
- System optimization
- ISO help
- Emergency help







## **Project Background**

#### LV-14 Master Meter Emergency

- 2/22/2018 GLWA pressure surge
- Loss of LV-14 source
- Multiple WM breaks in city
- City wide boil water advisory
- EB I-96 closed



NN ARROR

WEATHER

TRAFFIC

NEWSLETTERS

CONTACT US

M4 LIVE

## EB I-96 at Middlebelt in Livonia reopened after water main break

City under boil water advisory



A water main break closed I-96 in Livonia on Feb. 22, 2018. (WDIV)

**LIVONIA**, **Mich.** – Eastbound I-96 in Livonia has reopened after a water main break closed the freeway Thursday evening.









#### EB I-96 at Middlebelt in Livonia reopened after water main break

MI LIVE


City under boil water advisory




LIVONIA, Mich. - Eastbound I-96 in Livonia has reopened after a water main break closed the freeway Thursday evening.







#### EXHIBIT—A LV—14 STARK & SCHOOLCRAFT CITY OF LIVONIA



#### **Reactive Response**



- City Wide Boil Water Advisory
- Social Media Updates



## Critical User Impacts

- Michigan Dairy: Production Impacts
- Medical Care Facilities
- Hotels



- Guidance
- Hydraulic Modeling Analysis Recommendations





# **AWIA and Enhanced ERP 2018**

#### **AWIA 2018**


- America's Water Infrastructure Act (AWIA) Became Law: October 2018
- EPA Requirement: Risk and Resilience Assessment (RRA) Must Be Prepared
  - o Deadline for certification: December 31, 2020 (for population served between 50,000 and 99,999)
- Required Emergency Response Plan (ERP), 6 months after completing RRA
- Certify documents every 5 years



#### **Enhanced ERP**

#### **City Challenges**

- Aging assets
- Effective communication
- Detailed operational guidance
  - Emergency and planned disruptions
- Inexperienced workers








# Enhanced Emergency Response Plan

#### Goals

- Improve communication strategy
- Understand and model potential service disruption scenarios
- Document service disruption scenarios
- Educated inexperienced staff





#### **Critical Customers and Communication**



Understanding ALL Critical Customers and Their Needs

 Minimum pressure requirements



Communication Improvement

Documented list of:

- Contact name
- Contact number
- Contact email address



#### **Enhanced ERP Modeling**

- Emergency/Unplanned scenarios: max day system demands
- Planned service disruption scenarios: average day system demands

40+ Scenarios



Loss of Master Meter Feeds



Loss of Key City Facilities



#### **Level of Service Goals**

**Planned Service Disruptions** 

**Emergency Service Disruption** 

1

2

3

Strive to provide minimum desired pressure requirements at critical customers


Strive to provide 35 psi and above everywhere in the city's system


Strive to provide 20 psi and above everywhere in the city's system



#### **Model Organization**

#### **Scenarios**








#### **Data Set Nomenclature**

#### DATA SET NAME = SCENARIO NAME

- Valve Set
  - BASE if LOS goals are met with no changes
  - Unique/NEW if PRV settings changes are required to meet LOS goals
- Pipe Set
  - BASE if LOS goals are met with no changes
  - Unique/NEW if new WM is recommended to meet LOS goals
- Control Set
  - Unique/NEW Each scenario has a unique control set as valve closure/isolation is required for each scenario






#### **GIS Tool Creation**

- Improve workflow/increase project efficiency
- Combine data from pre and post model outputs
- Automatically calculated pressure difference between pre and post model outputs
- Remove unnecessary default model output data
  - o 47 fields to 12 fields








## **GIS** Layers are KEY

- Valves
- Water main
- Control valves
- Service leads





### **Workflow Summary**











Generate Baseline Files Hydraulic Analysis of Scenario Critical Customer Checks Regulatory Pressure Requirement Checks



#### **Workflow Summary Cont.**











Recommended System Changes Geoprocessing Tool


**ERP Deliverable** 





## **ERP Deliverable**

#### **ERP Deliverable**








## **Dashboard Demonstration**

#### **Emergency Response Plan Implementation**

- Review scenarios and recommendations with city staff
- Trial-Run of recommended system changes
  - GIS errors
  - Faulty valves
  - System limitations





# What's Next?

Tim Medearis, PE Autodesk

#### Safe Harbor Statement

The presentations during this event may contain forward-looking statements about our outlook, future results and related assumptions, total addressable markets, acquisitions, products and product capabilities, and strategies. These statements reflect our best judgment based on currently known factors. Actual events or results could differ materially. Please refer to our SEC filings, including our most recent Form 10-K and Form 10-Q filings available at <a href="https://www.sec.gov">www.sec.gov</a>, for important risks and other factors that may cause our actual results to differ from those in our forward-looking statements.

The forward-looking statements made in these presentations are being made as of the time and date of their live presentation. If these presentations are reviewed after the time and date of their live presentation, even if subsequently made available by us, on our website or otherwise, these presentations may not contain current or accurate information. We disclaim any obligation to update or revise any forward-looking statements.


Statements regarding planned or future development efforts for our products and services are not intended to be a promise or guarantee of future availability of products, services, or features but merely reflect our current plans and based on factors currently known to us. Purchasing decisions should not be made based upon reliance on these statements.


PLEASE NOTE: All Autodesk content is proprietary. Please Do Not Copy, Post or Distribute without authorization.

## **Drive Smarter Water Decisions**

#### What If You Could:

- Ensure Better Incident Responses
- Reduce Water Loss
- Increase Operator Productivity
- Promote Transparency
- Stretch Operating Expenses






#### **Break Impact Assessment**

Simulate a pipe break of estimated flow for any pipe in the system and understand the impact on customers. In addition, test out valve closure options to mitigate the system impact.


#### **Requirements:**

- Up-to-date hydraulic model of system
- Customer location points
- Isolation valve locations



#### Methodology


- User inputs pipe ID, time, duration, and flow estimate
- Info360 inserts emitter coefficient discharge in pipe to release specified flowrate
- Run model from designated time, applying initial conditions from SCADA where available
- Report all customers affected by pressure below service level for specified duration
- Find nearby closeable valves and offer scenarios to operate valves through the simulation and mitigate break impacts



# Your data can be a game-changer for:

- Non-revenue water
- Leakage Alerting
- Pump Performance
- Water Quality
- Hydraulic Model Calibration
- Operator Reporting
- Compliance

...and much more!





# Thank you! Ask your questions!

Susan Knepper, PE

**Water Resources Engineer** 

susan.knepper@ohm-advisors.com

Tim Medearis, PE

**Solutions Engineer** 

<u>Timothy.Medearis@autodesk.com</u>

